

## Technical Data Sheet

### KRONES hydrocare RO 2000

#### pH-adjustment

#### Product description and application

acidic solution for pH-correction (DIN EN 899)

Serves to adjust the pH value in order to ensure optimum conditions for sustainable plant operation.

#### Technical product data

pH-value	< 1
Density	1,27 – 1,29 g/cm <sup>3</sup> (at 20°C)
appearance	colorless liquid

#### Storage and shelf life

The product should be stored sealed in the original container in a cool, well ventilated place. Storage temperature: +10 °C - +25 °C. Minimum shelf life: 1 years.

#### Material safety data sheets

The current material safety data sheets are available for you to download from our website:  
[www.kic-krones.com/en/downloads.php](http://www.kic-krones.com/en/downloads.php)

You are also welcome to request them by e-mail to [kic@kic-krones.com](mailto:kic@kic-krones.com).

#### Labelling

Please refer to the corresponding material safety data sheet for details on:

- Hazardous goods labelling (section 2)
- Transport regulations (section 14)
- Safety regulations (section 4-8)

#### Application notes

When using the product, please observe the specifications of the machines and equipment used and the information in the safety data sheet.

#### Disposal note

Recycling of packaging only fully emptied and closed. Any product residues must be disposed of in accordance with local regulations. For further information, please refer to our material safety data sheet (section 13).

#### Further information

For more information, please contact [ki@kic-krones.com](mailto:ki@kic-krones.com) or visit the company website at [www.kic-krones.com](http://www.kic-krones.com).

#### Exclusion of liability

To the best of our knowledge, the information reflects today's know-how and experience of the Krones Group and does not include any guarantee of features, nor does it guarantee the suitability of the product for specific purposes. Legal liability cannot be deduced from information provided or from oral consultation. This product information is not subject to the updating service. It is mandatory to carry out a test run and an inspection of the features before the products are used.

**Status:** 10/2022